## **MALLEABLE IRON FITTINGS**



# Class 150 (Standard)




FIGURE 1105	Size		A		Unit Weight			
Straight Tee					Black		Galv.	
	NPS	DN	in	mm	lbs	kg	lbs	kg
	1/8	6	<sup>11</sup> / <sub>16</sub>	17	0.09	0.04	0.09	0.04
	1/4	8	<sup>13</sup> / <sub>16</sub>	22	0.15	0.07	0.15	0.07
	3/8	10	<sup>15</sup> / <sub>16</sub>	24	0.23	0.10	0.23	0.10
	1/2	15	1 <sup>1</sup> /8	29	0.41	0.19	0.41	0.19
	3/4	20	<b>1</b> <sup>5</sup> / <sub>16</sub>	33	0.60	0.27	0.60	0.27
	1	25	1 <sup>1</sup> / <sub>2</sub>	38	0.90	0.41	0.90	0.41
	1 <sup>1</sup> / <sub>4</sub>	32	13/4	44	1.31	0.59	1.31	0.59
	11/2	40	<b>1</b> <sup>15</sup> / <sub>16</sub>	49	1.73	0.78	1.73	0.78
← A →i	2	50	2 <sup>1</sup> / <sub>4</sub>	57	2.52	1.14	2.52	1.14
	21/2	65	211/16	68	4.90	2.22	4.90	2.22
A	3	80	31/16	78	7.13	3.23	7.13	3.23
	31/2	90	37/16	87	9.00	4.08	9.00	4.08
	4	100	3 <sup>13</sup> / <sub>16</sub>	98	11.32	5.13	11.32	5.13
→	5	125	41/2	114	19.42	8.81	19.42	8.81
<u> </u>	6	150	5 <sup>1</sup> /8	130	25.50	11.56	25.50	11.56

Note: See following page for pressure-temperature ratings. Galvanized weights may vary. Please contact your Anvil Representative if you need verification. All Elbows & Tees 3/s" (10 DN) and Larger are 100% Gas Tested at a Minimum of 100 PSI. (6.9 bar)

PROJECT INFORMATION	APPROVAL STAMP
Project:	☐ Approved
Address:	Approved as noted
Contractor:	☐ Not approved
Engineer:	Remarks:
Submittal Date:	
Notes 1:	
Notes 2:	

### MALLEABLE IRON FITTINGS





### **Malleable Iron Threaded Pipe Unions Pressure - Temperature Ratings Pressure Temperature Class 150 Class 250 Class 300** (°F) (°C) psi bar psi -28.9° -20° 300 20.7 500 34.5 600 41.4 to to 150° 65.6° 200° 93.3° 18.3 31.4 550 37.9 265 455 15.5 250° 121.1° 225 405 27.9 505 34.8 300° 148.9° 185 12.8 360 24.8 460 31.7 350° 176.7° 150 10.3 315 21.7 415 28.6 400° 204.4° 110 7.6 270 18.6 370 25.5 232.2° 325 450° 75 5.2 225 15.5 22.4 500° 260.0° 180 12.4 280 19.3 550° 287.8° 130 9.0 230 15.9

**Note**: Unions with Copper or Copper Alloy seats are not intended for use where temperature exceeds 450°F





For Listings/Approval Details and Limitations, visit our website at www.anvilintl.com or contact an Anvil Sales Representative.

Malleable Iron Threaded Fittings											
Pressure - Temperature Ratings											
		Pressure									
Temperature		Class 150		Class 300							
				Sizes ½"-1" (6-25 mm)		Sizes 1½"–2" (32–51 mm)		Sizes 2½"–3" (64–76 mm)			
(°F)	(°C)	psi <i>bar</i>		psi	bar	DSi	bar	psi	bar		
-20° to 150°	-28.9° to 65.6°		20.7	2,000	137.9	1,500	103.4	1,000	68.9		
200°	93.3	265	18.3	1,785	123.1	1,350	93.1	910	62.7		
250°	121.1	225	15.5	1,575	108.6	1,200	82.7	825	56.9		
300°	148.9	185	12.8	1,360	93.8	1,050	72.4	735	50.7		
350°	176.7	150	10.3	1,150	79.3	900	62.1	650	44.8		
400°	204.4	_	_	935	64.5	750	51.7	560	38.6		
450°	232.2	ı	-	725	50.0	600	41.4	475	32.8		
500°	260.0	_	_	510	35.2	450	31.0	385	26.5		
550°	287.8	_	_	300	20.7	300	20.7	300	20.7		

Anvil Class 150/300 Malleable Iron Fittings conform to ASME B16.3 and Unions conform to ASME B16.39.

ALL ELBOWS & TEES %" (10 DN) and LARGER ARE 100% GAS TESTED AT A MINIMUM OF 100 PSI. (6.9 bar)

Standards and Specifications									
	Dimensions	Material	Galvanizing*	Thread	Pressure Rating				
MALLEABLE IRON FITTINGS									
Class 150/PN 20	ASME B16.3	ASTM A-197	ASTM A-153	ASME B1 20.1	ASME B16.3				
Class 300/PN 50	ASME B16.3	ASTM A-197	ASTM A-153	ASME B1 20.1	ASME B16.3				
MALLEABLE IRON UNIONS									
Class 150/PN 20	ASME B16.39	ASTM A-197	ASTM A-153	ASME B1 20.1	ASME B16.39				
Class 250	ASME B16.39	ASTM A-197	ASTM A-153	ASME B1 20.1	ASME B16.39				
Class 300/PN 50	ASME B16.39	ASTM A-197	ASTM A-153	ASME B1 20.1	ASME B16.39				

<sup>\*</sup> ASTM B 633. Type I, SC 4, may be supplied as alternate zinc coating per applicable ASME B16 product standard.

### MALLEABLE IRON FITTINGS



# **General Assembly of Threaded Fittings**

- 1) Inspect both male and female components prior to assembly.
  - Threads should be free from mechanical damage, dirt, chips and excess cutting oil.
  - Clean or replace components as necessary.
- 2) Application of thread sealant
  - Use a thread sealant that is fast drying, sets-up to a semi hard condition and is vibration resistant. Alternately, an anaerobic sealant may be utilized.
  - Thoroughly mix the thread sealant prior to application.
  - Apply a thick even coat to the male threads only. Best application is achieved with a brush stiff enough to force sealant down
    to the root of the threads.
- 3) Joint Makeup
  - For sizes up to and including 2" pipe, wrench tight makeup is considered three full turns past handtight. Handtight engagement for 1/2" through 2" thread varies from 41/2 turns to 5 turns.
  - For  $2^{1}/2^{1}$  through 4" sizes, wrench tight makeup is considered two full turns past handtight. Handtight engagement for  $2^{1}/2^{1}$  through 4" thread varies from  $5^{1}/2$  turns to  $6^{3}/4$  turns.