

PVC Schedule 80 Pipe

PVC Schedule 80 Pipe, Type 1, Grade 1 - Belled End



PVC SCHEDULE 80 (GRAY)			BELLED-END			PVC 1120	
PART NO.	NOM. SIZE	UPC # 611942-	QTY. PER SKID	AVG. OD (IN.)	MIN. WALL (IN.)	MAX WORK PRESSURE AT 23° C OR 73° F	WT. PER 100 FT. (LBS.)
PVC 10005B	1/2" x 20'	04924	6880'	0.840	.147	850 PSI	20.3
PVC 10007B	3/4" x 20'	04925	4200'	1.050	.154	690 PSI	27.0
PVC 10010B	1" x 20'	04926	3540'	1.315	.179	630 PSI	40.5
PVC 10012B	1 1/4" x 20'	04927	4240'	1.660	.191	520 PSI	55.9
PVC 10015B	1 1/2" x 20'	04928	3300'	1.900	.200	470 PSI	67.7
PVC 10020B	2" x 20'	04764	1980'	2.375	.218	400 PSI	93.6
PVC 10025B	2 1/2" x 20'	04875	1360'	2.875	.276	420 PSI	142.8
PVC 10030B	3" x 20'	04776	960'	3.500	.300	370 PSI	191.1
PVC 10040B	4" x 20'	04774	1080'	4.500	.337	320 PSI	279.3
PVC 10060B	6" x 20'	04763	480'	6.625	.432	280 PSI	532.7
PVC 10080B	8" x 20'	04766	300'	8.625	.500	250 PSI	808.9
PVC 10100B	10" x 20'	04769	160'	10.750	.593	230 PSI	1199.3
PVC 10120B	12" x 20'	04771	120'	12.750	.687	230 PSI	1650.1
PVC 10140B	14" x 20'	04832	60'	14.000	.750	220 PSI	1930.0
PVC 10160B	16" x 20'	09372	60'	16.000	.843	220 PSI	2544.1

Note: Full pallets are polyethylene wrapped for cleanliness and UV protection.

 NSF Listed. Meets All Requirements of
 ASTM D 1784 and ASTM D 1785.


WARNING

Testing with or use of compressed air or gas in PVC / ABS / CPVC pipe or fittings can result in explosive failures and cause severe injury or death.

- NEVER test with or transport/store compressed air or gas in PVC / ABS / CPVC pipe or fittings.
- NEVER test PVC / ABS / CPVC pipe or fittings with compressed air or gas, or air over water boosters.
- ONLY use PVC / ABS / CPVC pipe or fittings for water or approved chemicals.
- Refer to warnings on PPFA's website and ASTM D 1785.

AIR/GAS