



SUBMITTAL INFORMATION


Repair Clamps - (FS3-xxxx-Length style)



THREE SECTION ALL STAINLESS STEEL REPAIR CLAMPS




Bolts & Nuts
18-8 type 304 stainless steel nuts and washers. Nuts are coated to prevent galling.



OUTLET THREAD TAP CODE

CC (AWWA) Thread		IP Thread	
Thread	Code No.	Thread	Code No.
3/4" CC	-CC3	3/4" IP	-IP3
1" CC	-CC4	1" IP	-IP4
1-1/4" CC	-CC5	1-1/4" IP	-IP5
1-1/2" CC	-CC6	1-1/2" IP	-IP6
2" CC	-CC7	2" IP	-IP7



NOM. PIPE SIZE	PIPE O.D. RANGE	LENGTH AND APPROX. WEIGHT (LBS.)					BOLT SIZE	BAND THICKNESS	CATALOG NUMBER	✓ SUBMITTED ITEM
		12.5"	15"	20"	24"	30"				
16"	15.92 - 17.12	31	40	52	64	77	5/8" 11 UNC	20 GA.	FS3-1712-Length	
	17.10 - 18.30								FS3-1830-Length	
18"	18.00 - 19.20	35	44	56	68	84			FS3-1920-Length	
	18.78 - 19.98								FS3-1998-Length	
	19.50 - 20.70								FS3-2070-Length	
20"	21.60 - 22.80	41	48	60	73	89			FS3-2280-Length	
	22.80 - 24.00								FS3-2400-Length	
	24.45 - 25.65								FS3-2565-Length	
24"	24.45 - 25.65	46	53	65	79	102			FS3-2700-Length	
	25.80 - 27.00								FS3-3082-Length	
	29.62 - 30.82								FS3-3242-Length	
30"	31.22 - 32.42	51	58	69	83	108				
Number of studs		12	12	18	21	27				

FEATURES

- NBR (Buna-N) gasket and conductivity strips are available
- Optional outlet taps are available for repair of service line pull-outs. Add tapping code to catalog number
- All welds are fully passivated to restore corrosion resistant characteristics of stainless steel
- UL Classified to ANSI/NSF Standard 61

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
Phone: 260-563-3171 / Fax: 800-826-3487
Overseas Fax: 260-563-0167
www.fordmeterbox.com

01/07/19

Submitted By: