

JSIS - EcoNet® Zoning

Job Details

Company Name:

Date:

Customer Name:

Customer Address:

Address line 2:

Compatible Equipment Information

Installation Date:

FURNACE

Model Number:

Serial Number:

Software Version*:

AIR HANDLER

Model Number:

Serial Number:

Software Version*:

COIL

Model Number:

Serial Number:

AIR CONDITIONER

Model Number:

Serial Number:

Software Version*:

HEAT PUMP

Model Number:

Serial Number:

Software Version*:

ECONET® SMART THERMOSTAT

Model Number:

Serial Number:

Software Version*:

ZONE THERMOSTAT

Model Number:

Serial Number:

Software Version*:

** Software versions for all equipment can be found in the EcoNet® Smart Thermostat Menu -> Service >*

FILTER

Size:

Type:

Description of Problem (Be Specific and include EcoNet® Fault Codes):

Zoning Application Details

What is the default minimum air flow required for this unit? Cooling CFM Heating CFM
 Is each zone (ductwork) sized to handle the minimum air flow for heating and cooling? Yes No
 How many zones? How many dampers? Size of dampers:
 Intelligent Bypass installed? Yes No Size of bypass Leaving/Supply Air Sensor
 Bypass Connected to zone 3 or zone 6?
 Over-conditioning enabled? Yes No
 How much over-conditioning is set at each zone control? zone2 zone3 zone4 zone5 zone6
 Zone Board #1 - Dip Switch 1 Position: Dip Switch 2 Position:
 Zone Board #2 - Dip Switch 1 Position: Dip Switch 2 Position:
 Secondary Transformer Installed? Yes No Transformers in phase should read 0 volts:

Startup & Commissioning

Enable zoning: Yes No Update zone ID assignments: Yes No
 Zoning checkout duct measurement %:
 Linearize dampers: Yes No Total static with all zones calling:

Zone 1 Airflow Limit: Blinking asterisks: Yes No
Airflow settings: Unlimited High Med-High Medium Med-Low Low
Static zone 1:

Zone 2 Airflow Limit: Blinking asterisks: Yes No
Airflow settings: Unlimited High Med-High Medium Med-Low Low
Static zone 2:

Zone 3 Airflow Limit: Blinking asterisks: Yes No
Airflow settings: Unlimited High Med-High Medium Med-Low Low
Static zone 3:

Zone 4 Airflow Limit: Blinking asterisks: Yes No
Airflow settings: Unlimited High Med-High Medium Med-Low Low
Static zone 4:

Zone 5 Airflow Limit: Blinking asterisks: Yes No
Airflow settings: Unlimited High Med-High Medium Med-Low Low
Static zone 5:

Zone 6 Airflow Limit: Blinking asterisks: Yes No
Airflow settings: Unlimited High Med-High Medium Med-Low Low
Static zone 6: